

Drinking Water State Revolving Fund Green Project Reserve  
- Preliminary -



**City of Iona Drinking Water Project**  
**SRF Loan #DW 1805 (pop. 1,803)**  
**\$1,133,250**

**Preliminary Green Project Reserve Justification<sup>1</sup>**

**Business Case GPR Documentation**

1. INSTALLS SCADA FOR REMOTE MONITORING (ENERGY Efficiency). GPR Business Case per 3.5-7: *automated and remote control systems (SCADA) that achieve substantial energy savings.* (\$xxxx).
2. INSTALLS ADVANCED FLUORESCENT LIGHTING (Energy Efficiency). GPR Business Case per 3.5-6: *Upgrade of lighting to energy efficient sources (such as...compact fluorescent, light emitting (LED) diode, etc).* (\$xxxxx)
3. INSTALLS PREMIUM ENERGY EFFICIENT MOTOR/VFD CONTROLLER FOR NEW WELL (Energy Efficiency). Business Case GPR per 3.5-1: *Energy efficient ...new pumping systems...including VFDs* (\$xxxxx).

The State of Idaho SRF Loan Program  
February 2018

<sup>1</sup> The loan recipient will update all information, including data in red font, in the GPR Technical Memorandum submission

# 1. SCADA CONTROL TECHNOLOGY

## Summary

---

- Energy efficiency from the installation of a SCADA system for remote electronic sensing of the water storage tank and pumping system.
- Loan amount = \$1,133,250
- Estimated energy efficiency (green) portion of loan = **x%** (**\$xxx**) (conceptual estimate)
- Estimated annual energy and labor savings = **\$xxxx** per year.

## Background/ Results<sup>2</sup>

---

- The SCADA system is part of the project at the well site pump house building.

## Energy Efficiency Improvements

---

- Remote SCADA monitoring saves labor costs = **x** people **y** hour per day = **\$xxxx/yr** in labor costs.

## Conclusion

---

- Total SCADA savings would be approximately **\$xxxx** per year in labor costs = payback of **z** years, therefore SCADA costs are GPR-eligible.
- **GPR Costs:**  
SCADA = **\$xxxx**  
Total = **\$xxxx**
- **GPR Justification:** SCADA system costs are GPR-eligible by a Business Case per 3.5-7<sup>3</sup>: *automated and remote control systems (SCADA) that achieve substantial energy savings.*

---

<sup>2</sup> 6-22-15 Correspondence with Project Manager

<sup>3</sup> Attachment 1, April 21, 2012 EPA Guidance for Determining Project Eligibility

## 2. Energy Efficient LIGHTING

### Summary

- Energy efficiency from the installation of advanced fluorescent lighting in the interior of the well site pump house building.
- Energy efficiency from the installation of light emitting diode (LED) lighting at the exterior of the well site pump house building.
- Loan amount = \$1,133,250
- Estimated energy efficiency (green) portion of loan = **x%** (**\$xxxx**) (conceptual estimate)
- Estimated annual energy savings = **\$xxx** per year.

### Background/ Results<sup>4</sup>

- The lighting system is part of the project at the well site pump house building.

### Energy Efficiency Improvements

- Energy efficient T-8 magnetic fluorescent lighting is approximately 28% more energy efficient than standard T-12 magnetic fluorescent lighting for relatively the same light output.<sup>3</sup>
- LED lighting is approximately 58% more energy efficient than typical high pressure sodium lighting for relatively the same light output.<sup>4</sup>



### Conclusion

- **GPR Costs:**  
Advanced Fluorescent Lighting = \$ **xxx**  
LED Lighting = \$ **xxxx**  
Total = \$ **xxxx**
- **GPR Justification:** Advanced fluorescent lighting and LED lighting is GPR-eligible by a Business Case per 3.5-7<sup>5</sup>: *Upgrade of Control Building lighting to energy efficient sources such as.....compact fluorescent, light emitting diode (LED).*

<sup>4</sup> 2-9-18 Discussion with Project Manager

### 3. ENERGY-EFFICIENT PUMP/ VFD

#### Summary

- The City will purchase and install premium energy-efficient vertical turbine pump in the new well and a variable frequency drives (VFDs).
- Loan amount = \$1,133,250
- Estimated energy efficiency (green) portion of loan = x% (\$xxxx) (conceptual estimate)

#### Background

- Provision of VFD on the pump will provide a much tighter range for pressure fluctuation. The VFD will save energy by assisting in maintaining constant system pressure; it will also reduce electrical consumption at times of pump start-up.

#### GPR Justification

##### Motors/VFDs:

The Baseline Standard Practice for comparison is a standard Epact motor that is not controlled by a VFD<sup>5</sup>. Published operating curves by the pump manufacturer provided VFD efficiency data:

- **Proposed Pump - no VFD, standard Epact efficiency motor**  
Type: Vertical Turbine Hollow Shaft  
Efficiency 82%; Flow 1,400 gpm; 2.02 mgd; Head 265 ft.  
Motor rating = 125 hp; Motor type = standard efficiency (93.0% assumed at 75% of full load<sup>6</sup>); existing avg. flow = 115 hp  
% operation = 33% (average day flow/pump output)  
% Annual Usage = 50% (average daily operation throughout the year)  
Energy usage = xxxxxx kW-hr
- **Proposed Pump - no VFD, with premium efficiency motor**  
(95.4% assumed at 75% of full load); existing avg. flow = 112.24 hp  
% operation = 33% (average day flow/pump output)  
% Annual Usage = 50% (average daily operation throughout the year)  
Energy usage = xxxxxx kW-hr
- **Proposed Pumps - VFD operation with premium efficiency motor**  
Efficiency 82%; Head 230 ft; Motor rating = 125 hp; Motor type = standard efficiency (95.4% assumed at 75% of full load); BHP, existing avg flow = 90.75 hp  
% operation = 33% (average day flow/pump output)  
% Annual Usage = 50% (average daily operation throughout the year)  
Energy usage = xxxxxx kW-hr



#### Conclusion

- By installing a premium pump/VFD in the new well, the City can save up to \$xxxx/yr. in energy costs
- The VFDs are cost effective as the payback period is less than the life of the equipment.
- **GPR Costs:** VFD = \$xxxxx
- **GPR Justification:** The VFD systems are Business Case GPR-eligible, qualifying per Sect. 3.5-1 (Energy Efficiency)<sup>7</sup>: “Energy efficient... new pumping systems... (including variable frequency drives (VFDs))” which are cost-effective.

<sup>5</sup> NYS Energy Research and Development Authority, Energy Evaluation Memorandum, Village of Greenport WWTP Upgrade 8-2009.

<sup>6</sup> [http://www.copper.org/environment/sustainable-energy/electric-motors/education/motor\\_text.html](http://www.copper.org/environment/sustainable-energy/electric-motors/education/motor_text.html)

<sup>7</sup> 2012 EPA Guidelines for Determining Project GPR-Eligibility. Attachment 2