



Line Leak Detector and Line Tightness Test Form

Inspection Date:

UST Facility	Person Conducting the Testing
Name: <input type="text"/> ID#: <input type="text"/>	Name: <input type="text"/>
Street Address: <input type="text"/>	Company Name: <input type="text"/>
City: <input type="text"/> Zip Code: <input type="text"/>	Address: <input type="text"/>
Site Contact: <input type="text"/> Phone: <input type="text"/>	Email: <input type="text"/> Phone: <input type="text"/>

Test Type	
<input type="checkbox"/> New Site	<input type="checkbox"/> Annual Test
<input type="checkbox"/> Line Tightness Test	<input type="checkbox"/> 3 gph Leak Detector
	<input type="checkbox"/> Retest after Repair or Modification
	<input type="checkbox"/> 0.2 gph Leak Detector
Testing equipment used: <input type="text"/>	
Technician certification #: <input type="text"/>	

Line Leak Detector Test Information and Results

- A 3 gph "Fail" is an automatic line leak detector that cannot detect a leak of 3 gph at 10 psi.
- A 0.2 gph "Fail" is an electronic line leak detector that cannot detect a leak of 0.2 gph at operating pressure.

Tank Number	Product Stored	Manufacturer	Model Number	Test Leak Rate		Other	Pass/Fail
				<input type="checkbox"/> 3 gph	<input type="checkbox"/> 0.2 gph		
				<input type="checkbox"/> 3 gph	<input type="checkbox"/> 0.2 gph		
				<input type="checkbox"/> 3 gph	<input type="checkbox"/> 0.2 gph		
				<input type="checkbox"/> 3 gph	<input type="checkbox"/> 0.2 gph		
				<input type="checkbox"/> 3 gph	<input type="checkbox"/> 0.2 gph		
				<input type="checkbox"/> 3 gph	<input type="checkbox"/> 0.2 gph		
				<input type="checkbox"/> 3 gph	<input type="checkbox"/> 0.2 gph		
				<input type="checkbox"/> 3 gph	<input type="checkbox"/> 0.2 gph		

Notes (replacement, etc.):

Tester's Signature (All testing was performed according to to manufacturer's instructions and 40 CFR 280.) Date

